

PRECAST SPANDREL
AS REQ'D. BY DESIGN

GRID

#4 REBAR INTO TOPPING AS REQ'D.
BY E.O.R. BEND DOWN AFTER TEE
IS SET IN PLACE

TOPPING AS REQ'D. BY E.O.R.
(BY OTHERS)

P-
201

P-
111

P-
120 OR AS REQ'D
BY DESIGN

$\frac{1}{2}$ " x 5" x 5"
BRG. PAD
AT EACH STEM

BRG. \emptyset IF REQ'D.
BY DESIGN

TEE DEPTH

$\frac{1}{2}$ "
1'-0"
MIN.

8"
MIN. 6"
MIN.

1'-2"
MIN.

ISSUED MAY 2015

REVISED

TEE BEARING CONNECTION
TO AN ARCHITECTURAL
SPANDREL WITH LEDGE

DT-15